Clay County Environmental Health
715 North 11th Street, Suite 303
Moorhead, MN 56560
218-299-5004

Daily Pool Chemistry Log Sheet

Month: _____/20_____

Facility Name:	CPO Name:	CPO #:	CPO Phone:	
Address:	Pool Desc:	Phone:	Pool Volume:	Occupancy:

DAILY TESTS AND SAFETY CHECKS												MAINTENANCE & NOTES
DATE	**Sanitizer Concentration (ppm)**				**pH** (7.2-8.0)	**Alkalinity** (60 – 150) ppm	**Water Temp.** (°F.)	**Cyan.** (35ppm Max)	**Drain Covers Secure?**	**Pressure** (PSI)	**Flow Rate** (GPM)	**Comments:** equipment, water added, clarity, accidents, chemicals added, repairs, ORP reading *Close pool if main drain cover is loose, missing, or broken.*
	Free Cl (Pool≥0.5, Spa≥2.0)		Combined Cl (<0.5) TC – FC = CC									
	Initial	Adjusted	Initial	Adjusted								
1												
2												
3												
4												
5												
6												
7												
8												
9												
10												
11												
12												
13												
14												
15												
16												
17												
18												
19												
20												
21												
22												
23												
24												
25												
26												
27												
28												
29												
30												
31												